



max. Prüfspannung U₀=2 kV
max. insulation test voltage U₀=2 kV

224,9	50	1250	3150	40,0	50,0	55	130	3	827 181 013
171	45	800	2500	25,0	40,0	39	102	2	827 181 012
171	45	630	2000	18,0	31,5	36	95	1	827 181 011
154,3	45	250	----	----	16,0	----	88	0	827 181 010
L2	L1	IN (A)	I _{test} 4min (A)	I _{sc} 3sec (kA)	I _{sc} 1sec (kA)	ØB	ØA	Größe	Nr. / No.

Allgemeintol. / general tol.		Maßstab / scale		Gewicht / weight (g)		Werkstoff num. / material no.		Werkstoff chem. / material chem.		Werkstoff Zustand / material state	
Tolerierung / tolerancing		1:1				Oberfläche / surface		Farbe / color			
Erstellt von / created by		Name / name		Datum / date		Beschreibung / title					
Geprüft von / approved by		Ferencsi		2010-04-15		CONNEX Erdungs und Stromprüf-Stecker Gr. 0, 1, 2 und 3					
		Dobler		2010-04-15		CONNEX Earthing and Current-Testing Connector s. 0, 1, 2 and 3					
Ersatz für / replacement for		Dokumentart / type of document		Dateiname / filename		Format / size		Blatt / sh.			
Für Kunden		S02-138393		A2		1/1					
And.nr. / rev. no.		And.datum / date of issue		Name / name		Index / rev.		Dokumentnr. / document no.			
		2010-05-20		Ferencsi		02		827181A			

PFISTERER
 Kontaktsysteme GmbH

The reproduction, distribution and utilization of this document as well as the communication of its contents to others without explicit authorization is prohibited. Offenders will be held liable for the payment of damages. All rights reserved in the event of the grant of a patent, utility model or design. © Pfisterer

